



Certificate of Conformity

Product Certification Scheme 5

Certificate No. P20612-01-15-INT

This certificate applies to the products

Passive infrared detectors

with name and/or type designation

NV35MR, NV35M and NV35MX

Placed on the market by

Paradox Security Systems Ltd.

780 Industriel Boulevard, St-Eustache, Québec, J7R 5V3, Canada

Produced in the manufacturing plant by

Paradox Security Systems Ltd.

780 Industriel Boulevard, St-Eustache, Québec, J7R 5V3, Canada

This certificate attests that all provisions concerning the assessment
and the performance described in the standard

EN 50131-2-2:2008

are applied and that the products fulfil all the prescribed requirements

This Certificate is valid until 2019-07-03

Høvik, Norway 2015-07-03

For Applica Test & Certification AS

A handwritten signature in blue ink that reads 'Vibeke Vigmostad'.

Vibeke Vigmostad, Certification Manager



Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2015-07-03

Product(s) Covered by this Certificate		
Product Name	Product Description	Applied Standards
NV35MR	Passive infrared detector Wire-free (One way communication)	EN 50131-1:2006/A1:2009 EN 50131-2-2:2008 EN 50131-6:2008/A1:2014 (NV35MR only)
NV35M	Passive infrared detector	EN 50130-4:2011
NV35MX	Wired	EN 50130-5:2011

Product(s) Specifications		
Product Name	Security Grade	Environmental Class
NV35MR	Grade 2	Class IV
NV35M	Grade 3	
NV35MX		

Application/Limitation

- Suitable for indoor application

Document(s) Reviewed	
Document ID	Description
PARIAS_EN 50131-2-2.26142_rev1	Test report according to: EN 50131-2-2:2008
PARENV_EN 26732	Test report according to: EN 50130-5:2011
BIS/REC/1331	Test report according to: EN 50130-5:2011, Clause 17
PAREMC_EN.26732	Test report according to: EN 50130-4:2011
PARIAS_EN50131-6_TypeC.26146	Test report according to: EN 50131-6:2009/A1:2014
Report No.4008752	FPC Audit/Inspection Report, 2013-10-22

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the product(s) listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The product(s) listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design or construction of the product(s)
- Changes or amendments in the standard(s) which form the basis for documenting compliance with the requirements
- Customer fails to comply with the agreed surveillance of the Factory Production Control and/or Quality System

END OF CERTIFICATE