



The mentioned product
complies with the
mentioned test
requirement

Intertek LSS Scheme Tick Mark Certificate

18LHK1206-01

In accordance with the Tick Mark Rules and Certification System 5,
as defined in ISO / IEC 17067:2013, we certify that the product(s)

MG5050 Wireless Control Panel

is in conformity with the following standard(s):

**EN50131-1:2006+A1, EN50131-3:2009, EN50131-5-3:2005+A1,
EN50136-1:2012, EN50136-2:2013, EN50131-6:2008+A1**

Report Number(s):

100803903MIN-001, 100803903MIN-002, 100803903MIN-009B, 100803903MIN-011,
100803903MIN-012, 101264280MIN-001, PARIAS_EN 50136.29953, PARIAS_EN 50131-4.31289_2

Paradox Security Systems

780 Industrial Blvd, St-Eustache, Quebec, J7R 5V3, Canada

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the
above mentioned product(s)

This certificate is valid until:

20 February 2020

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee, and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification Body:	ITCL
	LSS Reference:	LSS 0901
	Issued Date:	28 September 2018

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



010

Certification Officer

Nick Jones





The mentioned product
complies with the
mentioned test
requirement

Intertek LSS Scheme Tick Mark Certificate

18LHK1206-01

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 1

Brand and Type/Model	Description	Factory Code
Paradox MG5050	Wireless Control Panel	PARADOCA.01

Security Grade: 2

Environmental Class: II

ATS Class: 2

Zone options: 5 onboard zones.

ANNEX No. 2

Rating: 16.5 VAC (50 or 60Hz) minimum 20 VA

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.